



REQUISITION FOR AUTHORITY FOR EXPENDITURE

COMPTROLLER'S COPY

(Form 1363)

Applicant's No. 138 Eng. Dept. No. 11(1914) Comptroller's No. 9

On Puget Sound Location Optg. Dept. State of Wash. Val. Sec. No. 6

Authority is requested for an expenditure of \$ 280.00 279.00 chargeable approximately as follows: (Distribution to be made in General Office, St. Paul)

To Optg. Exps. \$ 27.00 To Addns. and Belts \$ 253.00

For new work At Seattle, Wash.


Consisting of Rearrange heating system Pier #1.

The location is on this company's property and is not in joint territory. To secure required rights it will be necessary

If required by Accounting Department, a detailed estimate will be furnished promptly after approval. The expenditure is recommended for the following reasons: (if space is not sufficient continue on back.)

By reason of so much unoccupied space under radiation at Pier No. 1, and certain tenants requiring heat at irregular hours, it is found necessary to rearrange steam pipes, shut off valves, etc., to prevent unnecessary condensation and regulate supply in temperate weather. Entire structure at present has continual supply of steam furnished.

This improvement has been inspected by Division Superintendent, Supervisor and Division Engineer, on the ground, and recommended accordingly. These changes are being made for the purpose of reducing the monthly bill for furnishing steam, which it will do materially.



Work should be commenced At once in order to complete by and be done by company force under charge of Division Superintendent.

Signature and Title of Applicant J. M. McLaughlin Date of Requisition Dec. 17, 1913

APPROVED BY Genl. Supr. Chief Engr. M. of H.

Chief Engr., Mech. Supr. or Supt. Telg. General

Third Vice President. Second. Comptroller. Date of Final Approval JAN

COMPTROLLER'S RECORD OF NOTICE OF APPROVAL AND OF COMPLETION 1845 issued 191 Work begun 191 Work finished

