

Form 1345 1922

COMPTROLLER'S COPY

1922

NORTHERN PACIFIC RAILWAY COMPANY

AUTHORITY FOR EXPENDITURE

Year: ~~1921~~ 1922

Superintendent's No. 100
No.

Dept. No. Engineering Dept. No. ~~1000~~

A. F. E. No. 89

Lake Superior Div. Third District State Minn. Val. Sec. No. 2

AUTHORITY IS REQUESTED FOR A NET EXPENDITURE OF \$ 7567.00

Accounting distribution as follows: (Distribution to be made in General Office.)

DEPRECIATION DOCUMENT 15100 EXTENDED BY LAIRBIRD

	Operating Expenses	Profit and Loss	Net Operating Expenses	Net Profit and Loss
Cost of property retired	\$ 3000	\$	\$	\$
Value of salvage	300		2700	
Incidental costs			536	
Total in Operating Expenses				\$ 8836
Total to Profit and Loss				300
To Material and Supplies				
To Bills for Collection				
To Other Accounts				
Net charge to investment account				
Final distribution				

Budget reference

Class of Work: No. 30

Joint facility contract reference: U.M. & St.P. Ry., October 1, 1900, Art. II.

The location is - - - on this company's property. To secure rights ^{Original Cost Adjustment 1923} will be necessary...

Location: Wyoming, Minnesota

Title and Reason: New stand pipe and rebuild water tank in new location.

The present water tank at Wyoming (48,000 gallons capacity) located on 3rd sub-division, Main Line is failing and must be replaced. It was first proposed to rebuild the tank, but later it was thought that it could be patched up to carry it over this year, but it is now conceded that it will be a mistake to patch up this tank at this time and instead a new tank should be built on the location away from Main Line, which can be done without interfering with the present layout. It was also originally proposed to install an additional water column to be

Work to be done by ^{Over} company force under charge of ~~XXXXX~~ superintendent

Accounting to concentrate in the office of Superintendent Duluth

Signature and Title *[Signature]* superintendent Date Nov 1st 19 21

APPROVED: *[Signature]* General Superintendent *[Signature]* Engr. Maint. of Way. Assistant General Manager.

Mech. Supt. Supt. Tel. or Signal Engr. *[Signature]* Chief Engineer *[Signature]* General Manager *[Signature]* Vice President.

[Signature] General Auditor, Comptroller. *[Signature]* President. Date of First Approval JAN 1 1922

COMPTROLLER'S RECORD OF NOTICE OF APPROVAL AND OF COMPLETION

Form No. 1345 issued FEB 2 1922 Work begun 19 Work finished JAN 26 1922

located north of depot, which would expedite the running of trains,
but we can get through the winter with the car now on the south of
depot, letting this work be carried over until next spring; but we
should rebuild the tank without delay owing to its dilapidated condi-
tion, and it is my recommendation that this authority be granted without
delay.

Pennsylvania Ave

Proposed 12" Dia Pipe

Superior

Proposed 12" Dia Pipe

Proposed 12" Dia Pipe

Proposed 12" Dia Pipe

W-31

Proposed New Stand Pipe and New Loc of Water Tank

Wyoming Minn

Office of Dist Engr St Paul, Minn

Prepared by Markham & Co

Valuation Sec No 2 of Minnesota



N 100'

50'

Street

18178' H.S.