



N. P. 1363
6-24

NORTHERN PACIFIC RAILWAY COMPANY

COMPTROLLER'S COPY

AUTHORITY FOR EXPENDITURE

1929 ⁹²⁹
YEAR 1929

SUPERINTENDENT'S No. 55

DEPT. No. 31

A. F. E. NO. 220

No.

ENGINEERING DEPT. No. 121

Rocky Mtn

Div. Third

DISTRICT STATE
BRANCH Montana

VAL. SEC. No. 5

AUTHORITY IS REQUESTED FOR A NET EXPENDITURE OF \$ 1140

Accounting distribution as follows: (Distribution to be made in General Office.)

	Operating Expenses	Profit and Loss	Net Operating Expenses	Net Profit and Loss
Cost of property retired	\$ 1400		\$ 1400	
Value of salvage				10
Incidental costs				
Total to Operating Expenses				\$ 1410 ✓
Total to Profit and Loss				
To Material and Supplies				
To Bills for Collection				
To Other Accounts				
Net charge to investment account—Additions and Betterments				(270) ✓
Total of distribution				\$ 1140 ✓

Original Cost Adjustment
Made in 819 1921
J. J. [Signature]

Budget reference: ~~NOT~~ IN BUDGET ITEM 390-1927

Class of Work: No. 17 ✓

Joint facility contract reference: NOT JOINT ACCOUNT

The location is on this company's property. To secure rights, it will be necessary

Location: Missoula - Montana

Title: Missoula - Change in Stockyard Water Supply

Reason: At present we obtain water for the stockyards from the City through 1856 feet of 2" pipe which supplies a small water tank. This line is old, in poor condition, and furnishes an inadequate supply when there is a large number of stock to feed and water. It is probable that there are a number of leaks in the line and the City water rate is high. The City main is small and in poor condition but the City will not rehabilitate it. It will cost less to drill a well and install our own supply than to rebuild the pipe line, and the operating cost of the pumping will be much less than paying the City water rent. Electricity is available and the stockyard foreman will do the pumping.

Work to be done by company force under charge of Superintendent

Accounting to concentrate in the office of Superintendent

Signature and Title: *J. J. [Signature]* Superintendent

Checked by Chief Engineer

Date Jan. 1 19 29


APPROVED: <i>[Signature]</i> General Superintendent.	<i>[Signature]</i> Asst. Chief Engr. or Engr. in Charge	<i>[Signature]</i> General Manager.
Mech. Supt., Supt. Telph. or Signal Engr.		
<i>[Signature]</i> Chief Engineer.		<i>[Signature]</i> Vice President.
<i>[Signature]</i> For Comptroller.	<i>[Signature]</i> President.	Date of Final Approval { FEB 5 1929 }

COMPTROLLER'S RECORD OF NOTICE OF APPROVAL AND OF COMPLETION

Form No. 1345 issued 19... Work begun 19... Work finished 19...

122

To Paradise
4" M.B. I



Amalg. Surfact. Spur

6437+223 E.E. 5th. Yds.

Proposed 10x10 frame pump house over
prop'd 185 ft. 5" drilled well
6436+71. Ctr. old 16' φ Water Tank Rt.

Transformer on pole

Prop'd pipe
Prop'd elec. line

lightning arrester & ground wr. on pole

BATH

Abandon 1836 sq. ft. of 2" M.L.P. placed 1004-07 I

Present 2-wr. 3500 V. sq. phase, 60 cyc., pow. line 5 (Imp'd 1501-22)

4" sewer

Food

N.P. 75/94. I

Elv. line. I

609+229

E.M. Div.
Proposed to replace
from City's con
and elec
Office Dist. Engineer
Prop'd no
Violation

