



N. P. 1363  
6-24

# NORTHERN PACIFIC RAILWAY COMPANY AUTHORITY FOR EXPENDITURE

COMPTROLLER'S COPY  
1929  
YEAR 1929

SUPERINTENDENT'S No. 18  
No.

DEPT. No.  
ENGINEERING DEPT. No. 20

A. F. E. No. 345

Lake Superior Div.

Third DISTRICT STATE Minn.  
BRANCH

VAL. SEC. No. 3

AUTHORITY IS REQUESTED FOR A NET EXPENDITURE OF \$ 1173.00  
Accounting distribution as follows: (Distribution to be made in General Office.)

	Operating Expenses	Profit and Loss	Net Operating Expenses	Net Profit and Loss
Cost of property retired				
Value of salvage	946			
Incidental costs	115			
Total to Operating Expenses			831	
Total to Profit and Loss			198	
To Material and Supplies				1029 ✓
To Bills for Collection				115 ✓
To Other Accounts				
Net charge to investment account—Additions and Betterments				
Total of distribution				145 ✓

Budget reference: Item 450 Added to July 1931 Adjusted Month DEC 1931 1287 ✓

Joint facility contract reference: Joint with CMStP&P RR Contract Oct. 1, 1900. Valuation Class of Work: No. 20 ✓

The location is \_\_\_\_\_ on this company's property. To secure rights, it will be necessary

Location: Wyoming

Title: Replace gas engine pump with 5 x 6 Duplex power pump with electric motor, at Water Tank.  
Reason: This is one of our most important water stations as the majority of our freight trains take water at this point. The present pumping plant has been in use a great many years and is in poor condition and should be renewed. On account of the condition of the plant and its location being some distance from the depot, it is necessary to employ an exclusive pumper. It is, therefore, proposed to replace the gasoline pumping plant with an electric power plant, which will permit the operation of pump by telegraphers, doing away with the exclusive pumper and effect a saving of approximately \$800.00 a year.

Work to be done by company force under charge of Superintendent

Accounting to concentrate in the office of Superintendent

Signature and Title: *H. Jacobus* Superintendent

Checked and Entered  
President's Office




Superintendent Date Jan. 4, 1929

APPROVED: <i>N. H. Strachan</i> General Superintendent.	<i>W. H. ...</i> Asst. Chief Engr. or Engr. in Charge of Work.	<i>W. H. ...</i> General Manager.
<i>Bernard ...</i> Mech. Supt., Supt. Telgr. or Signal Engr.		
<i>W. H. ...</i> Chief Engineer.		
<i>Charles ...</i> For Comptroller.		<i>W. H. ...</i> Vice President.

COMPTROLLER'S RECORD OF NOTICE OF APPROVAL AND OF COMPLETION


Form No. 1345 issued \_\_\_\_\_ 19\_\_\_\_ Work begun \_\_\_\_\_ 19\_\_\_\_ Work finished Dec 17 29



F.M. & Co. Type N. Gas Eng. #26199. 8 H.P.  
 N.P. & Co. Eclipse Pump Ser. #W 326.  
 Double Acting 6" Cyl. 18" Stroke.  
 N.P. & Co. #11. (To be removed)

Section through Water Tank & Well.  
 1" = 20'

Drilled hole through rock



Plans for Prop'd Motorizing of Pumping  
 Unit to be furnished on approval of R.R.

N.P. Ry.  
 Lake Superior Div. 3rd Dist.  
 Prop'd Changes in Pumping Station at  
 Wyoming  
 Scales as shown  
 Office of Dist. Engr., St. Paul, Minn. 9/1928.  
 New Work Shown Red  
 Val. Sec. Minn. #2.